

LICENCE

No. 23322 replaces No.23102

Issued to:
Applicant:
Preflexibel NV
Elisabethlaan, 153
9400 NINOVE
Belgium

Licensee:
Preflexibel NV
Elisabethlaan, 153
9400 NINOVE
Belgium



Product : conduit systems for cable management
Trade name(s) : PREFLEX, PREFLEXIBEL, QUICKFLEX
Type(s)/model(s) : PRF 16, PRF 20, PRF 25, PRF 32, PRF 40


The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1235


SGS CEBEC hereby grants the right to use the CEBEC certification mark
The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on : 14/03/2025


ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee

BELAC
005-PROD



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. A
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	conduit systems for cable management
Trade name(s)	:	PREFLEX, PREFLEXIBEL, QUICKFLEX
Type(s)/Model(s)	:	PRF 16, PRF 20, PRF 25, PRF 32, PRF 40
description	:	Conduit systems for electrical installations Pliable self recovering conduits
design	:	With or without UV compound With or without low friction internal layer
nominal size(s) (outside diameters)	:	16, 20, 25, 32, 40 mm
classification	:	3422 / 3342
type of conduit	:	non-metallic / corrugated
method of connection	:	non-treadable
degree of protection	:	Ip44
resistance to bending	:	pliable / self-recovering
Fire propagation	:	non flame propagation
colour(s)	:	all excepted Red, Orange & Yellow

Additional information

CLASSIFICATION CODING

First digit : 3	Heavy compression strength	750 N
Second digit : 4	Medium impact strength	2 kg/100 mm
or 2	Heavy impact resistance	2 kg/300 mm
Third digit : 2	Minimum permanent application and installation temperature	-25°C / -5°C
Fourth digit : 2	Maximum permanent application and installation temperature	+90°C
Fifth digit : 3	Resistance to bending Pliable/self-recovering	

DECLARED INTERNAL DIAMETERS

Conduit Dia 16 mm : 10.60
Conduit Dia 20 mm : 14.10

Conduit Dia 25 mm : 18.30
Conduit Dia 32 mm : 23.00
Conduit Dia 40 mm : 30.00

TESTS

Test requirements

NBN EN 61386-1 based on EN 61386-1:2008 + A1:2019
NBN EN IEC 61386-22 based on EN IEC 61386-22:2021 + A11:2021

Test results

The test results are laid down in test report ref. 623273.01, 601421.01, 634037.01a, 634037.01b, 634037.01c and 634259.04

Remarks

Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 14/03/2025

Certification Manager :

 2025-03-14

FACTORY LOCATION(S)

Preflexibel NV
Elisabethlaan, 153
9400 NINOVE
Belgium